The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

Original & 1st copy – Ecology, 2nd copy – owner, 3rd copy – driller

Construction/Decommission *("x" in circle)*

(X) Construction

( ) Decommission *ORIGINAL INSTALLATION Notice of Intent Number* 209445

CURRENT
Notice of Intent No. W226728
Unique Ecology Well ID Tag No. APG454
Water Right Permit No. L
Property Owner Name UCAN Properties
Well Street Address
City _____ County OKANOGAN
Location NE 1/4-1/4 SW 1/4 Sec 6 Twn 39 R 27 E or WWM (circle one)
Lat/Long (s, t, r Still REQUIRED) Lat Deg _____ Lat Min/Sec _____
Long Deg _____ Long Min/Sec _____
Tax Parcel No.

PROPOSED USE: (X) Domestic ☐ Industrial ☐ Municipal ☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other

TYPE OF WORK: Owner's number of well (if more than one)
(X) New well ☐ Reconditioned *Method:* ☐ Dug ☐ Bored ☐ Driven ☐ Deepened ☐ Cable ☐ Rotary ☐ Jetted

DIMENSIONS: Diameter of well 6 inches, drilled 527 ft.
Depth of completed well 527 ft.

CONSTRUCTION DETAILS
Casing Installed: (X) Welded 6" Diam. from +2 ft. to 20 ft.
☐ Liner installed ___" Diam. from ___ ft. to ___ ft.
☐ Threaded ___" Diam. from ___ ft. to ___ ft.

Perforations: ☐ Yes (X) No
Type of perforator used
SIZE of perfs ___ in. by ___ in. and no. of perfs ___ from ___ ft. to ___ ft.

Screens: ☐ Yes (X) No ☐ K-Pac Location
Manufacturer's Name
Type Model No.
Diam. ___ Slot size ___ from ___ ft. to ___ ft.
Diam. ___ Slot size ___ from ___ ft. to ___ ft.

Gravel/Filter packed: ☐ Yes (X) No ☐ Size of gravel/sand
Materials placed from ___ ft. to ___ ft.

Surface Seal: (X) Yes ☐ No To what depth? 20 ft.
Material used in seal Granular Bentonite
Did any strata contain unusable water? ☐ Yes (X) No
Type of water? Depth of strata
Method of sealing strata off

PUMP: Manufacturer's Name
Type: H.P.

WATER LEVELS: Land-surface elevation above mean sea level ___ ft.
Static level 180 ft. below top of well Date 9-23-06
Artesian pressure ___ lbs. per square inch Date ___
Artesian water is controlled by (cap, valve, etc.)

WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? ☐ Yes (X) No If yes, by whom?
Yield: ___ gal./min. with ___ ft. drawdown after ___ hrs.
Yield: ___ gal./min. with ___ ft. drawdown after ___ hrs.
Yield: ___ gal./min. with ___ ft. drawdown after ___ hrs.
Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test ___ gal./min. with ___ ft. drawdown after ___ hrs.
Airtest TRACE gal./min. with stem set at ___ ft. for ___ hrs.
Artesian flow ___ g.p.m. Date
Temperature of water ___ Was a chemical analysis made? ☐ Yes ☐ No

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information. (USE ADDITIONAL SHEETS IF NECESSARY.)

MATERIAL	FROM	TO
Dirt & Gravel	0	12
Limestone & Shale	12	146
Damp Shale	146	151
Limestone & Shale	151	280
Damp Limestone	280	291
Limestone & Shale	291	438
Fine Limestone	438	455
Limestone & Shale	455	527

Start Date 9-23-06 Completed Date 9-23-06

DEPT OF ECOLOGY Received OCT 4 2006 CENTRAL REGIONAL

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

(X) Driller ☐ Engineer ☐ Trainee Name (Print) Daniel BOConnell
Driller/Engineer/Trainee Signature Daniel BOConnell
Driller or trainee License No. 358

Drilling Company O'Connell Drilling
Address 650 Pearl Hill Rd
City, State, Zip Bridgeport WA 98813
Contractor's Registration No. OCONNDO848K Date 9-25-06

If TRAINEE,
Driller's Licensed No.
Driller's Signature

Ecology is an Equal Opportunity Employer.

 The Department of Ecology does NOT warranty the Data and/or Information on this Well Report.